

Ecotherm Surface Temperatures

Testing at the AGA Laboratories in Los Angeles, CA indicated the following results:

	(A) Top center of cabinet	(B) 2½" above unit on plywood
14,000 Btu's	<u>180.1° F</u>	<u>147.0° F</u>
6,000 Btu's	<u>132.4° F</u>	<u>121.8° F</u>

AGA standards require that wall surface temperatures (B) should not exceed 90° F above ambient room temperature.

